




# ***Projects Completed Successfully***




**Pressure Vessels  
& Reactors**




**Heat Exchangers**




**Storage Tanks**



**Process Columns**



**ASME Audits Participated**



U U2 S R CE

# ***Engineering – Capability***

---

## **Codes and Standards**

- American Standards: ASME Sec. VIII Div I, II, III
- European Standards: EN 13445
- British Standards: BS PD 5500
- German Standards: AD Merkblätter
- Russian Standards: GOST
- Australian Standards: AS
- Indian Standards: IS
- DIN
- AD 2000
- API 650, API 620
- UL-142, UL-58

## **Software Capabilities**

- PV Elite 2018
- Ansys R19
- CAESER-II
- SOLIDWORKS
- STAAD Pro V8i
- Nozzle Pro
- Auto CAD 2019

# Design – Pressure Vessel

- **Scope:**
  - ✓ Static design as per ASME section VIII div-I
- **Application:** Pretreatment Vessel for Chemical Plant
- **Size:** ID 3000 mm
- **Pressure:** 3 bar at 350 deg C
- **Deliverables:**
  - ✓ Design calculation report
  - ✓ Manufacturing drawing
- **Software Used:** PV Elite

## Input Data

OPERATING AND DESIGN DATA			2
UNITS			3
Type	Vert / Horiz	Vertical	4
Operating Fluid / Content	Vessel-Grade PA, Nozz. Jacket- SL / SM Steam, Limpet Coil- Terminal 66		5
Fluid / Content Characteristics	Vessel-(Organic Acids), Nozz. Jacket- None, Limpet Coil- None		6
Additional Requirements	No		7
Statutory Requirements	NO		8
Design Code	"U" Stamp	ASME Sec VIII Div 1 2015 Edition with latest Errata	9
Operating Temperature	°C	Vessel-280 Nozz. Jacket-165 / 204 Limpet Coil- 320	10
Operating Pressure	bar(a)	Vessel-1.05 Nozz. Jacket-7 / 16 Limpet Coil- 5	11
Max. Operating Static Head	m	5.4 from bottom tan line	12
Density of Operating Fluid	kg/m <sup>3</sup>	Vessel-1002 Nozz. Jacket- Limpet Coil- -	13
Internal Design Pressure	bar(g)	Vessel-3 Nozz. Jacket-10 / 22 Limpet Coil- 10	14
External Design Pressure	bar(g)	FV for Nozzle Jacket	15
Design Temperature	°C	Vessel-350 Nozz. Jacket-200 / 230 Limpet Coil- 350	16
Min. Design Metal Temperature	°C	10	17
Max. Allowable Working Pressure	bar(g)	-	18
Is designed for "STEAM OUT" condition?	Yes/ No	No	19
"F" / "E" Steam Temperature	°C	-	20
Steam pressure	bar(g)	-	21
Is NACE Code Applicable?	Yes/ No	No	22
Hydrostatic test pressure (Shop / Site)	bar(g)	As per code	23
Corrosion Allowance	mm	NIL	24
Corrosion Allowance on internals	mm	0	25
Post Weld Heat Treatment	Yes/ No	As per code	26
Radiography: Shell / Dished end / Cone	Shell Spot / Head - 100%	-	27
Joint Efficiency: Shell / Dished end / Cone	0.85 / 1.0	-	28
Wind Design Code	IS-475 Part 3 (Ed. 2015) Amd-1	-	29
Seismic Design Code	IS-1893 Part 1 - 6th Edition 2016, Part 4 2015, Importance Factor 1.5, Category 2, Zone II, Zone Factor Z = 0.16, R = 2.0, Soil Type = Type II (Medium Soil), VR ratio shall be 1	-	30
			31
			32


## Output- PV Elite

PROJECT - IGPL PA-IV/MA-4 PROJECT  
DATA SHEET No. 1922-402-04-P441D-A4-101 REV. 1  
4TH PRETREATMENT VESSEL (TAG No. P-441D)  
PV Elite 2016 SP1 Licensees: P.E.D.CONSLTANTS  
FileName : P-D441 REV  
Input Echo : Step: 1 8:36pm Dec 26,2018

### PV Elite Vessel Analysis Program: Input Data

PROJECT - IGPL PA-IV/MA-4 PROJECT  
DATA SHEET No. 1922-402-04-P441D-A4-101 REV. 1  
4TH PRETREATMENT VESSEL (TAG No. P-441D)

Design Internal Pressure (for Hydrotest) 0.3000 MPa  
Design Internal Temperature 350 °C  
Type of Hydrotest UG-99 (b) Note [36]  
Hydrotest Position Vertical  
Projection of Nozzle from Vessel Top 550.00 mm  
Projection of Nozzle from Vessel Bottom 80.000 mm  
Minimum Design Metal Temperature 10 °C  
Type of Construction Welded  
Special Service None  
Degree of Radiography RT-4  
Use Higher Longitudinal Stresses (Flag) Y  
Select t for Internal Pressure (Flag) N  
Select t for External Pressure (Flag) N  
Select t for Axial Stress (Flag) N  
Select Location for Stiff. Rings (Flag) N  
Consider Vortex Shedding N  
Perform a Corroded Hydrotest Y  
Is this a Heat Exchanger No  
User Defined Hydro. Press. (Used if > 0) 0.0000 MPa  
User defined MAWP 0.0000 MPa



## Output- Drawing

# Design – Shell & Tube Heat Exchanger

- **Scope:** Design Of Shell and Tube Heat Exchanger as per ASME section VIII div-2
- **Application:** Propane Chiller For Oil & Gas Industry
- **Size:** 967 Sq. Mtr
- **Pressure:** 120 bar at 110 deg C (Shell & tube side)
- **Deliverables:**
  - ✓ Design calculation report
  - ✓ Manufacturing drawing
- **Software Used:** PV - Elite

## Input Data

Shell-and-tube heat exchanger:				horizontal / vertical		Case:		Controlling case:	
TEMA type : BKU				floating head / floating head with tube side bellows / hairpin / fixed tube sheet / fixed tube sheet with expansion joint in shell					
PROCESS DATA				Shell side		Tube side		SKETCH	
Name of fluid				Propane		Wet Gas			
Fluid flow rate				kg/h		121.84			
- total									
- liquid in / out				21.63 0.00		0.45 2.33			
- vapour in / out				9.10 30.729		121.39 119.51			
Temperature inlet				°C		55.0 34.48			
Pressure at inlet				bar (abs)		96.9			
				9.9					
Pressure drop				calculated / allowed		0.02 0.3			
Velocity				calculated (IT7) allowed (18)		m/s 0.21 10.05(9)			
Film coefficient (1)				average		m²/m³K 710.23			
Fouling resistance (1)						0.00018 0.00022			
Average wall temperature of shell / tubes				°C		29.21 33.75			
Total heat duty				kW		Thermopump recycles. Static head from column			
Effective temp. difference				13		liquid level to bottom tube sheet/level			
Overall coefficient clean (2)				1045.85		Kettle Minimum hold-up capacity			
Overall coefficient fouled (2)				644.72		Condenser: Number of tubes submerged			
				°C					
Total number of shells				1		Total required surface per unit		958.7 m²	
Connected in series				1 in parallel		1		Total effective surface of unit	
								912.2 m²	
								Effective surface per shell	
								912.2 m²	
CONSTRUCTION DATA PER SHELL				Number of passes shell side		1			
Shell inside diameter				2188.0		mm		single + double overnormal / ASTM / support only	
Blindside dia (outer tube limit)				1498.0		mm		Baffle type:	
Number of passes tube side				2		mm		Baffle orientation:	
Number of tube holes per tube sheet:				2430		mm		Outer baffle out: % Overlap	
Type of tube				bare/finned		mm		tube rows	
Tube OD (plain end)				19		mm		Baffle spacing center: 641	
Tube wall thickness				2		mm		Baffle spacing inlet/outlet: 640	
Tube length (straight)				6100		mm		Baffle thickness: 14	
Tube pitch				25		mm		Number of cross passes: 1	
Tube lay-out angle				30 / 45 / 60 / 90		deg		Number of pairs of sealing strips: 1	
								Impingement protection/zipper pipe below inlet nozzle: yes/no	
Estimated mass per shell				82300		kg			
Dry				94350		kg			
Wet				21100		kg			
Blindside only									
NOZZLE DATA				Shell side		Tube side			
				Inlet Outlet		Inlet Outlet			
Nozzle DN				12" (N3)		16" (N4 A/B)		20" (N1)	
Velocity				m/s 7.24 6.99		8.57		20" (N2)	
								7.61	
				Shell side		Tube side			

Notes:

1) Film coefficients and fouling resistance are related to their own surface

2) Overall coefficients are related to the outer diameter of the tubes

3) Due to piping and safety requirements exchanger will be elevated 9 meter above ground level

4) Design codes: ISO 9812 - DEP 312(0),30-Gen - TEMA-A / ASME Sec. VII Div 2 - DEP 312(0),31-Gen

5) Material selected as per DEP 312(0),30-Gen

6) Gasket selected as per DEP 312(0),30-Gen

7) All the vented parts (tube side) shall be suitable for Sour Service application & shall be in compliance with "NACE MR 0175 1500 / ISO 15848 / ISO 15848" in addition, all pressure retaining carbon steel materials shall be supplied in normalized condition.

8) Earthing boss in accordance with STD-4-0304-001

9) Allowed velocities in accordance with TEMA and DEP 312(0)7 requirements

Design Code No.:


Conf. Job No.:

MSDC No.:

Page:

# Design – Pressure Vessel

- **Scope:**
  - ✓ Static design as per ASME section VIII div-I
- **Application:** Flare KO Drum
- **Size:** ID 3300 mm
- **Pressure:** 3.5 bar at 350 deg C
- **Deliverables:**
  - ✓ Design calculation report
  - ✓ Manufacturing drawing
- **Software Used:** PV - Elite



## Input Data

DESIGN DATA				
INSTALLATION	OUTDOOR	CODE	ASME SECT. VIII DIV. 1, 2015 Ed. + PROJ. SPECIFICATIONS	
ASME STAMP		VESSEL	YES	JACKET
QUANTITY	1			
CAPACITY	68 m <sup>3</sup>			
CONTAINED FLUID	NAME	NITROGEN/HYDROCARBONS		LIQ. STEAM
	PHYSICAL STATE	VAPOUR/LIQUID		VAPOUR/LIQUID
	DENSITY	1.31/630.5		1000
	FLUID HAZARDOUSNESS	240		000
	LETAL/TOXIC (TRACER)	N/A		N/A
SERVICE	NET HEN/STRESS/OTHERS	N/A		N/A
	DESIGN	1st. cond.	350	270
	DESIGN	2nd. cond.	—	180
	DESIGN	3rd. cond.	—	—
TEMPERATURE (SEE NOTE "M")	°C	OPERATING	85	180
MINIMUM DESIGN METAL TEMPERATURE (SEE NOTE "E")	°C	—29	—29	—29
	DESIGN	1st. cond.	3.5	5.5
	DESIGN	2nd. cond.	—	FULL VACUUM
	DESIGN	3rd. cond.	—	—
PRESSURE bar (a) (SEE NOTE "K, M")	OPERATING	0.09+0.345	3.5	—
HYDROTEST PRESSURE	bar (a)	ACCORDING TO CODE	ACCORDING TO CODE	—
PNEUMATIC TEST PRESSURE	bar (a)	—	—	—
CORROSION ALLOWANCE (SEE NOTE "O")	mm	3	3	—
POSTWELD HEAT TREATMENT	NONE	NONE	NONE	—
RADIOGRAPHY	SPOT	SPOT	SPOT	—
WELDING EFFICIENCY	0.85	0.85	0.85	—
INSULATION	TYPE/THK.	PP / 85 (SEE NOTE "L")	PP/PHOSPHOS	YES (HOLD)

## Output- PV Elite

### PV Elite Vessel Analysis Program: Input Data

Low pressure pe flare ko drum  
Tag No 9133

Design Internal Pressure (for Hydrotest) 0.3500 MPa  
Design Internal Temperature 350 °C  
Type of Hydrotest UG-99(b)  
Hydrotest Position Horizontal  
Projection of Nozzle from Vessel Top 0.0000 mm  
Projection of Nozzle from Vessel Bottom 0.0000 mm  
Minimum Design Metal Temperature -29 °C  
Type of Construction Welded  
Special Service Air/Water/Steam  
Degree of Radiography RT-4  
Use Higher Longitudinal Stresses (Flag) Y  
Select t for Internal Pressure (Flag) N  
Select t for External Pressure (Flag) N  
Select t for Axial Stress (Flag) N  
Select Location for Stiff. Rings (Flag) N  
Consider Vortex Shedding N  
Perform a Corroded Hydrotest Y  
Is this a Heat Exchanger No  
User Defined Hydro. Press. (Used if > 0) 0.0000 MPa  
User defined MAWP 0.0000 MPa  
User defined MAPNC 0.0000 MPa


## Output- Drawing

# Design – Pressure Vessel

- **Scope:**
  - ✓ Static design as per AD 2000
- **Application:** CO2 Rectifier-Reboiler
- **Size:** ID 450 mm
- **Pressure:** 20 bar at 30 deg C
- **Deliverables:**
  - ✓ Design calculation report
  - ✓ Manufacturing drawing
- **Software Used:** NA

## Output Calculation Data

Design Data			
Construction Code	AD 2000 MERKBLATT (ED. SEPTEMBER 2016)		Clause
PED categories	IV	SEP	
PED module	G	-	
Fluid type / Group	Gas / 2		
Pressure X Volume ( Bar X L )	8660		
Stress category	I		Clause 3, W10
Test Group	8		Table 1a, HPO
Material sub group	8.1		Table 1a, HPO
Type of Vessel	Horizontal		
	Shell	Coil	
Internal Design Pressure	20	20	Bar(g)
Design Temperature for Internal Pressure	30	30	°C
External Design Pressure	NA	NA	Bar(g)
Operating Pressure (Min / Max)	15 to 17	15 to 17	Bar(g)
Operating Temperature (Min / Max)	-35 to 15	-35 to 15	°C
Minimum Design Metal Temperature	-45	-45	°C
MAWP (Same as design pressure)	20	20	Bar(g)
Pneumatic Test Pressure at the top of Vessel	28.6	28.6	Bar(g)
Corrosion allowance	Nil		
Radiography Marking	Spot		Table 1b, HP 0
Joint Efficiency	0.85		Table 1b, HP 0
Specific Gravity of Content	Negligible		
Service	CO2 Gas		
Test Media	Air		
Empty / Operating Weight	505		Kg
Test Weight	505		Kg
Post Weld Heat Treatment	No		Table 1b', HP 0
Post Forming Heat treatment	No		Clause 2.2.3, HP 7/3
Impact Test	No		Table 1, W10
Shell Inside Diameter	450		mm
Shell Length ( W/L - W/L )	1800		mm
Vessel Volume	312	6.2	liters
Wind data	EN 1991-1-4:2005 (Design wind speed 31.5 m/s. Terrain Category-O)		
Seismic data	G Loading, I = 1.25, Gx=Gy=Gz=0.07		
Inspection opening requirement	Yes		Table 'I', A5 & Appx. A5



### DESIGN DATA :-

Design Code:	AD 2000
Operating Temperature	-35 °C to 15 °C
Operating Pressure	15 to 17 Bar g
Design Temperature	-45 °C to 30 °C
Design Pressure	20 Bar g

### \* Test Pressure

Pneumatic (Vessel)	22 Bar g
Coil testing (Pneumatic)	22 Bar g
** Hydraulic	NA

\* = Pressure shall be held at test pressure for 1 hr and next 8 hrs at working pressure/ design pressure.  
\*\* = NA.

Radiography	Spot 10%
Corrosion Allowance	Nil

# Design – Cyclone Separator

- **Scope:**
  - ✓ Static design as per ASME section VIII div-I
  - ✓ FE Analysis
- **Application:** Decoke Cyclone
- **Size:** ID 700 mm
- **Pressure:** 0.5 bar at 320 deg C
- **Deliverables:**
  - ✓ Design calculation report
  - ✓ Manufacturing drawing
- **Software Used:** PV-Elite, Ansys


## Input Data

DESIGN DATA	
DESIGN CODE	: ASME SECT. VIII DIV.1 (only design & calculation)
INSPECTION BY	: RELIANCE / TPB AND/OR NOMINEE
REGULATION	: -
WIND CODE	: INDIAN STANDARD IS875 (PART 3) 1987
EARTHQUAKE CODE	: IS1893 (PART 4)
SERVICE	DECOKE CYCLONE
FLUID	STEAM / AIR / SOLIDS
OPERATING PRESSURE	kg/cm <sup>2</sup> g (See Note 1. from PDS)
OPERATING TEMPERATURE	Deg C (See Note 1. from PDS)
FLUID DENSITY	(See PDS)
DESIGN PRESSURE	kg/cm <sup>2</sup> g 0.5 + FULL OF WATER
AT DESIGN TEMPERATURE	Deg C 320
EXT. DESIGN PRESSURE	kg/cm <sup>2</sup> g -
AT DESIGN TEMPERATURE	Deg C -
M.D.M.T AT DESIGN PRES	Deg C 7.5
INTERNAL CORROSION	mm (See Note 13. from PDS)
JOINT EFFICIENCY	0.85
STRESS RELIEVED	PER CODE
RADIOGRAPHIC EXAMINATION	SPOT
SHOP TEST PRESSURE	kg/cm <sup>2</sup> g PER CODE & SPEC.
PAINTING / PAINTING AREA	- / m <sup>2</sup> PER SPEC. / *
INSULATION THICKNESS	mm PER SPEC. (Note 10. from PDS)
CAPACITY	m <sup>3</sup> LATER
CODE STAMP	NO
NO. OF ITEMS	1

## Output- PV Elite

### PV Elite Vessel Analysis Program: Input Data

Design Internal Pressure (for Hydrotest)	0.1079	MPa
Design Internal Temperature	320	°C
Type of Hydrotest	UG-99(b) Note [36]	
Hydrotest Position	Vertical	
Projection of Nozzle from Vessel Top	0.0000	mm
Projection of Nozzle from Vessel Bottom	0.0000	mm
Minimum Design Metal Temperature	6	°C
Type of Construction	Press. Welded	
Special Service	Air/Water/Steam	
Degree of Radiography	RT-3	
Use Higher Longitudinal Stresses (Flag)	Y	
Select t for Internal Pressure (Flag)	N	
Select t for External Pressure (Flag)	N	
Select t for Axial Stress (Flag)	N	
Select Location for Stiff. Rings (Flag)	N	
Consider Vortex Shedding	Y	
Perform a Corroded Hydrotest	Y	
Is this a Heat Exchanger	No	
User Defined Hydro. Press. (Used if > 0)	0.0000	MPa
User defined MAMP	0.04503	MPa
User defined MAPnc	0.0000	MPa



## Output- Drawing



# Design – Pressure Vessel


- **Scope:**
  - ✓ Static design as per PD 5500
- **Application:** Surge Vessel
- **Size:** ID 3000 mm X Length 22000 mm
- **Pressure:** 20 bar at 50 deg C
- **Deliverables:**
  - ✓ Design calculation report
  - ✓ Manufacturing drawing
- **Software Used:** PV Elite

## PV Elite Vessel Analysis Program: Input Data

Project : WATER SECURITY MEGA RESERVOIRS PACKAGE B PRPS 2 - UMM  
 Project Code : GTC 626/2014  
 SURGE VESSEL DIA. 3000 X 22000 LG.

Design Internal Pressure (for Hydrotest) 2 MPa  
 Design Internal Temperature 50 °C  
 Hydrotest Position Horizontal  
 Projection of Nozzle from Vessel Top 0 mm  
 Projection of Nozzle from Vessel Bottom 0 mm  
 Minimum Design Metal Temperature 0 °C  
 Use Higher Longitudinal Stresses (Flag) Y  
 Select t for Internal Pressure (Flag) N  
 Select t for External Pressure (Flag) N  
 Select t for Axial Stress (Flag) N  
 Consider Vortex Shedding N  
 Perform a Corroded Hydrotest Y  
 Is this a Heat Exchanger No  
 User Defined Hydro. Press. (Used if > 0) 3 MPa  
 User defined MAWP 0 MPa  
 User defined MAProc 0 MPa

## Output –PV Elite



Output- Drawing

DESIGN DATA		
CONSTRUCTION CODE	PD 5500 : EDITION 2016	
ENQUIRY CASES	5500/82, 5500/91	
CERTIFICATION MARK	NOT APPLICABLE	
NATIONAL BOARD REGISTRATION	NOT REQUIRED	
MANUFACTURER SERIAL NO.	REFER NOTE 7	
INSPECTION	IN-HOUSE / CLIENT	
EXAMINER No.	SS241-9/1, SS241-9/2, SS241-9/3, SS241-9/4 SS242-9/1, SS242-9/2, SS242-9/3, SS242-9/4	
JOB No.	XXXXXX-CA-SE-101	
DESIGN (INT/EXT)	NP4	2.0 / 0.055
OPERATING (INT/EXT)	NP4	0.55 / N/A
HYDROTEST AT TOP OF VESSEL	NP4	3.0
	USER DEFINED TEST PRESSURE GREATER THAN PRESSURE AS PER S&S-1	
MAWP (INTERNAL) (HOT & CORRODED)	NP4	2.0 @ 50°C (SAME AS DESIGN PRESSURE)
MAWP (EXTERNAL)	NP4	0.55 @ 50°C (SAME AS DESIGN PRESSURE)
DESIGN (INT/EXT)	°C	50 / -
OPERATING (MAX/MIN)	°C	TBA
HYDROTEST	°C	0 °C @ 2.0 MPa
METAL TEMPERATURE DURING HYDROTEST	°C	NOT LESS THAN 17 & NOT BE MORE THAN 48
OPERATING MEDIUM	WATER	
CAPACITY (FULL / WORKING)	CU M	102.00 / 151
MEDIUM DENSITY	KG/CU M	1000
CORROSION ALLOWANCE (INT/EXT)	(mm)	3/ML (INTERNALLY RUBBER LINED - 3 THK EPDM)
CONSTRUCTION CATEGORY	CATEGORY 2	3.4.1
PHOTOGRAPHY	LONG SEAM	SPOT TORE + ALL 'T' JOINTS
	CIRC. SEAM	SPOT TORE + ALL 'T' JOINTS
JOINT EFFICIENCY	LONG SEAM	NOT APPLICABLE
	CIRC. SEAM	NOT APPLICABLE
PAINT		EXEMPTED
IMPACT TESTING		EXEMPTED
SPECIAL SERVICE		NO
INSPECTION OPENING REQUIREMENT	YES (PROVIDED NOZZLE N10)	
WIND LOAD	NO-6300 PRIT 2, 1987, DESIGN WIND SPEED 180 KM/H	YES 29.12.11
SEISMIC LOAD	ASCE 7.2.10.10, 10-0.00, 11-0.045, 1-1.00, SITE CLASS : B	3.2.1
INSTALLATION	HORIZONTAL	
INSULATION	TYPE / THK	NA
FIREPROOFING	TYPE / THK	NA
HYDRO TEST POSITION	HORIZONTAL	

Input Data



## ***Design – Shell & Tube Heat Exchanger***

- **Scope:** Design Of Shell and Tube Heat Exchanger as per ASME section VIII div-1

- **Application:** Wash Water Heater
- **Size:** 42.9 KW
- **Pressure:** 19 bar at 150 deg C (Shell & tube side)
- **Deliverables:**
  - ✓ Design calculation report
  - ✓ Manufacturing drawing
- **Software Used:** PV - Elite

## Input Data

## Output –PV Elite

**PV Elite Vessel Analysis Program: Input Data**


Wash Water Heaters  
02-01-B-1231/1241 A/B  
Rev 2

### Exchanger Design Pressures and Temperatures

Shell Side Design Pressure	19.000	bar
Channel Side Design Pressure	18.000	bar
Shell Side Design Temperature	90	°C
Channel Side Design Temperature	90	°C

```
Type of Hydrotest
Hydrotest Position
Projection of Nozzle from Vessel Top
Projection of Nozzle from Vessel Bottom
Type of Construction
Special Service
Degree of Radiography
Use Higher Local Thermal Stresses (Flag)
Select t for Internal Pressure (Flag)
Select t for External Pressure (Flag)
Select t for Axial Stress (Flag)
Select Local Thermal Stresses (Flag)
Consider Vortex Shedding
Perform a Corroded Hydrotest
Is this a Heat Exchanger?
User defined Hydro. Press.. (Used if > 0)
User defined MAWP
User defined MAPRC
```




DESIGN CONDITIONS				ASME SECC-VI, DIV.1, 2007 ADD 2008+TEMA CLASS "F", TYPE-A			
STAMP	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO	18	18 / IV	18 / IV	YES	NO
PRESSURE	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO					
TEMPERATURE			Bar	18 / IV	18 / IV		
HYDROTEST PRESSURE			"C	99	99		
HEAT (AT MAX)			"C	0.3107	0.6721		
STEAMOUT PRESSURE			"C	-287C @ 0.2388	-287C @ 0.5028		
STEAMOUT TEMPERATURE			Bar	3.5	3.5		
RADIOGRAPHY (SHELL/HEAD)			"C	150	150		
JOINT EFFICIENCY (SHELL/HEAD)			—	100%	100%		
WARP AT DESIGN TEMPERATURE			—	1.0/1.0	1.0/1.0		
WARP IN TEST			Bar	0.3388	0.5028		
MAP (HEAT AND COLD)			Bar	0.2380	0.517		
INSULATION			TYPE/THK.	YES	YES		
FIREPROOFING				SADDLE ONLY			
CORROSION ALLOWANCE			mm	0	0		
NO. OF PASSES				1	6		
TOTAL FLOW RATE			kg/h	—	—		
STRESS RELIEVING						YES	NO
FULL VACUUM REQUIRED						YES	NO
POST WELD HEAT TREATMENT						YES	NO
LETHAL SERVICE						YES	NO
FLAMMABLE SERVICE						YES	NO
EXPLOSIVE SERVICE						YES	NO
REQUIRED	<input checked="" type="checkbox"/>	TO GUIDE				BY CLIENT	
<input type="checkbox"/> NOT REQUIRED							
				SHLL-HEAD			
				PIPING			
				FORWINGS			
				STANDARDS FORWINGS			
				BOLTS AND NUTS			
				CODE			NOTES
				REC-2009			
WIND	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO	BS 6399-97 DESIGN WIND SPEED	83.6 Km/Hr.			
SEAQUAKE	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO					



## Output- Drawing

# FEA – Fatigue Analysis Of Iron Ore Bin

- **Scope:**
  - ✓ Static design as per ASME section VIII div-I
  - ✓ Fatigue life evaluation for pressure fluctuation as per ASME section VIII div-II
- **Application:** Blast furnace
- **Deliverables:**
  - ✓ Design calculation report
  - ✓ Fatigue analysis report
  - ✓ Manufacturing drawing
- **Software Used:** Ansys



Document No.: PED/FEA/2012-13/WELMON/001	Rev. 1	Sheet: 19 of 31
Document Title: FATIGUE ANALYSIS REPORT OF IRON ORE PRESSURIZED BINS		

And the Stress factor used to compute  $X = Y = \left( \frac{S_a}{C_w} \right) \cdot \left( \frac{E_{FC}}{E_T} \right)$

$$= (77.67075 / 6.894757) * (195000 / 200133)$$

$$= 10.9762614$$

Exponent used to calculate permissible number of cycles = X =

$$X = \frac{C_1 + C_3Y + C_5Y^2 + C_7Y^3 + C_9Y^4 + C_{11}Y^5}{1 + C_2Y + C_4Y^2 + C_6Y^3 + C_8Y^4 + C_{10}Y^5}$$

$$X = 7.10594$$






Calculated using C1 – C11 coefficients listed in table 3.F.2 listed below -

Coefficients	$77.2 \leq S_a \leq 296 (MPa)$
$C_i$	$11.2 \leq S_a \leq 43 (ksi)$
1	1.608291E+01
2	-4.113828E-02
3	-1.023740E+00
4	3.544068E-05
5	2.896256E-02
6	1.826072E-04
7	3.863423E-04
8	0.0
9	0.0
10	0.0
11	0.0

The Number of allowable fatigue cycles  $N = 10^X = 10^{7.10594} = 12,762,624$

# FEA – Analysis Of Vessel


- **Scope:** Verify filter plate design as per ASME section VIII div-II
- **Application:** Water Treatment
- **Deliverables:** FEA report static linear analysis
- **Software Used:** Ansys



# ***FEA – Piping Analysis***



---

- **Scope:**
  - ✓ Analysis of piping joints for thermal loads.
  - ✓ Structural & transient analysis
- **Deliverables:**
  - ✓ FEA report as per ASME section VIII div-II,
  - ✓ Design calculations as per ASME section VIII div-I,
  - ✓ Manufacturing drawings
- **Software Used:** Ansys



# FEA – Cargo Vessel LPG Bullet


- **Scope:**
  - ✓ FEA Static Structural analysis to verify thickness
  - ✓ Verification of Support members
- **Deliverables:**
  - ✓ FEA report
  - ✓ Design calculation as per ASME section VIII div-I/ASME section XII
  - ✓ Manufacturing **drawings**
- **Software Used:** Ansys






# CFD – Cooling Tower Buffer Tank


- **Scope:** Calculate the transient force acting on the tank cylinder
- **Deliverables:** CFD report
- **Software Used:** Fluent



CAD Model



Fluid Volume



CFD Meshing

